

CERTIFICATE



SKZ - Testing GmbH awards the following company

Jansen AG Kunststoffwerk
Industriestrasse 34
CH-9463 Oberriet SG

Production site: Jansen AG Kunststoffwerk, CH-9463 Oberriet SG

the right to use the **SKZ**-mark



A 141

for the following plastic products

**Heating pipes made of PB-H and PB-R, with oxygen barrier,
3-layer, production group 1 ($d_n \leq 63$ mm)**

Material	Dimension	Application class	
		4	5
PB-H	8 x 1.0 mm, 14 x 2.0 mm, 14.5 x 1.8 mm, 16 x 2.0 mm, 17 x 2.0 mm, 18 x 2.0 mm	10 bar	10 bar
	10 x 1.0 mm, 12 x 1.3 mm, 15 x 1.5 mm (variant 2), 20 x 2.0 mm	10 bar	8 bar
	15 x 1.5 mm (variant 1)	8 bar	6 bar
PB-R	14 x 2.0 mm, 14.5 x 1.8 mm, 16 x 2.0 mm, 17 x 2.0 mm	10 bar	10 bar
	8 x 1.0 mm, 18 x 2.0 mm	10 bar	8 bar
	10 x 1.0 mm, 12 x 1.3 mm, 15 x 1.5 mm (variant 2), 20 x 2.0 mm	8 bar	8 bar
	15 x 1.5 mm (variant 1)	6 bar	6 bar

according to **SKZ-Specification for Tests and Inspection HR 3.4:2013-05**.

Users of the **SKZ**-mark are obliged to observe the required regulations for the production and testing of these products.

Date of initial certification: 8 January 2002

Date of expiry: 13 January 2031

Würzburg, 14 January 2026



i. V.

Dipl.-Ing. (FH) Michael Klute

Deputy Head of Certification Body

The original language of this certificate is German. In case of doubt, the German version is obligatory.

SKZ - Testing GmbH, Friedrich-Bergius-Ring 22, 97076 Würzburg, Germany | Tel. +49 931 4104-0, testing@skz.de, www.skz.de
The Certification Body of SKZ - Testing GmbH is accredited by DAkkS according to DIN EN ISO/IEC 17065:2013 under the number D-ZE-19033-01.