

SKZ - Testing GmbH awards the following company

Jansen AG Kunststoffwerk
Industriestraße 34
CH-9463 Oberriet SG

Production site: Jansen AG Kunststoffwerk, CH-9463 Oberriet SG

the right to use the **SKZ**-mark



A 325

for the following plastic products

**Heating pipes made of PE-RT Type I, with oxygen barrier,
5-layer, production group 1 ($d_n \leq 63$ mm)**

Dimension	Application class	
	4	5
14 x 2.0 mm, 16 x 2.0 mm	8 bar	6 bar
8 x 1.0 mm, 10 x 1.3 mm, 12 x 1.3 mm, 17 x 2.0 mm, 18 x 2.0 mm, 20 x 2.0 mm, 26 x 3.0 mm, 32 x 3.0 mm	6 bar	4 bar

according to **SKZ-Specification for Tests and Inspection HR 3.16:2024-02**.

Users of the **SKZ**-mark are obliged to observe the required regulations for the production and testing of these products.

Date of initial certification: 8 January 2002

Date of expiry: 13 January 2031

Würzburg, 14 January 2026



i. V.
Dipl.-Ing. (FH) Michael Klute
Deputy Head of Certification Body